



## Environmental Services Analysis Report - Final

**Invoice Number:** 1077808  
**Sample Location:** WTP  
**Collected by:** Sid Sirota  
**Station #:** SK05HA0001

**Permit:** 2070  
CABRI DIST.SYSTEM

**Collected Date:** 08-Aug-2016 8:00 AM  
**Received:** 09-Aug-2016 9:21 AM  
**Reported:** 16-Aug-2016 8:58 AM  
**Water Source:** Distributed

**Submitted By:**  
CABRI TOWN OF  
BOX 200  
CABRI, SK  
S0N 0J0

**Invoice:**  
CABRI TOWN OF  
BOX 200  
CABRI, SK  
S0N 0J0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
General Chemistry/Water Quality Panel					94.50
Conductivity	3074	µS/cm	< 2300		
pH	6.9	pH Units	6.5 - 9.0		
Total Alkalinity	89.6	mg/L CaCO3	< 500		
Phenol Alkalinity	0.00	mg/L CaCO3	No Guideline		
Bicarbonate	109	mg/L	No Guideline		
Carbonate	0	mg/L	No Guideline		
Hydroxide	0	mg/L	No Guideline		
Chloride Dissolved	64.4	mg/L	< 250		
Fluoride Dissolved	<0.05	mg/L	< 1.5		
Nitrate Dissolved	<0.2	mg/L	< 45		
Sulfate Dissolved	1638.0	mg/L	< 500		
Total Hardness (Calculated)	1206	mg/L CaCO3	< 800		
Total Dissolved Solids	2592	mg/L	< 1500		
Iron	<0.1	mg/L	< 0.3		
Manganese	0.03	mg/L	< 0.05		
Calcium	229	mg/L	No Guideline		
Magnesium	154	mg/L	< 200		
Potassium	14	mg/L	No Guideline		
Sodium	383	mg/L	< 300		