

SRC Group # 2019-4735

May 01, 2019

Town of Cabri
Box 200
202 Centre Street
Cabri, SK S0N 0J0
Attn:

Date Samples Received: Apr-24-2019

Client P.O.:

All results have been reviewed and approved by a Qualified Person in accordance with the Saskatchewan Environmental Code, Corrective Action Plan Chapter, for the purposes of certifying a laboratory analysis

Results from Lab Sections 1 and 2 have been authorized by Keith Gipman, Supervisor
Results from Lab Section 3 and 7 have been authorized by Pat Moser, Supervisor
Results from Lab Sections 4 and 5 have been authorized by Vicky Snook, Supervisor
Results from Lab Section 6 have been authorized by Marion McConnell, Supervisor

-
- * Test methods and data are validated by the laboratory's Quality Assurance Program.
 - * Routine methods follow recognized procedures from sources such as
 - * Standard Methods for the Examination of Water and Wastewater APHA AWWA WEF
 - * Environment Canada
 - * US EPA
 - * CANMET
 - * The results reported relate only to the test samples as provided by the client.
 - * Samples will be kept for 30 days after the final report is sent. Please contact the lab if you have any special requirements.
 - * Additional information is available upon request.

This is a final report.

SRC Group # 2019-4735

May 01, 2019

Town of Cabri
 Box 200
 202 Centre Street
 Cabri, SK S0N 0J0
 Attn:

Date Samples Received: Apr-24-2019

Client P.O.:

19721 SK05HA0001 04/22/2019 09:00 TOWN OF CABRI - CLINIC *WATER*

Analyte	Units	19721
Lab Section 3 (Organics)		
Monochloroacetic acid	ug/L	<10
Monobromoacetic acid	ug/L	<2
Dichloroacetic acid	ug/L	<3
Trichloroacetic acid	ug/L	10
Dibromoacetic acid	ug/L	<3
Total haloacetic acids, 5 (calc.)	ug/L	10
Total haloacetic acids, 6 (calc.)	ug/L	10
Bromochloroacetic acid	ug/L	<3
THM1: Chloroform	ug/L	14
THM2: Bromodichloromethane	ug/L	7.2
THM3: Chlorodibromomethane	ug/L	3
THM4: Bromoform	ug/L	<2
Total trihalomethanes (calc.)	ug/L	24.2

Symbol of "<" means "less than". This indicates that it was not detected at level stated above.

The temperature of the cooler was 19 °C upon receipt.