

**Environmental Services Analysis Report - Final**

<b>Invoice Number:</b> 1178581	<b>Collected Date:</b> 30-Oct-2023 9:00 AM
<b>Sample Location:</b> WTP	<b>Received:</b> 31-Oct-2023 9:28 AM
<b>Collected by:</b> Sid Sirota	<b>Reported:</b> 03-Nov-2023 4:12 PM
<b>Station #:</b> SK05HA0001	<b>Water Source:</b> Distributed
<b>Permit:</b> 2070	
CABRI DIST.SYSTEM	

<b>Submitted By:</b>	<b>Invoice:</b>
CABRI TOWN OF	CABRI TOWN OF
BOX 200	BOX 200
CABRI, SK	CABRI, SK
S0N 0J0	S0N 0J0

Analysis	Result	Unit	Sask Guideline	Test Comment	Fee
General Chemistry/Water Quality Panel					104.00
Conductivity	1477	µS/cm	< 2300		
pH	7.4	pH Units	7.0 - 10.5		
Total Alkalinity	109	mg/L CaCO3	< 500		
Phenol Alkalinity	0.00	mg/L CaCO3	No Guideline		
Bicarbonate	133	mg/L	No Guideline		
Carbonate	0	mg/L	No Guideline		
Hydroxide	0	mg/L	No Guideline		
Chloride Dissolved	32.8	mg/L	< 250		
Fluoride Dissolved	0.06	mg/L	< 1.5		
Nitrate Dissolved	0.5	mg/L	< 45		
Sulfate Dissolved	646.5	mg/L	< 500		
Total Hardness (Calculated)	584	mg/L CaCO3	< 800		
Total Dissolved Solids	1149	mg/L	< 1500		
Iron	<0.1	mg/L	< 0.3		
Manganese	0.03	mg/L	< 0.05		
Calcium	130	mg/L	No Guideline		
Magnesium	63	mg/L	< 200		
Potassium	18	mg/L	No Guideline		
Sodium	125	mg/L	< 300		