

April 23, 2026

306-741-9850

Via Email: townofcabri@sasktel.net

Town of Cabri
Box 200
CABRI SK S0N 0J0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for the Town of Cabri: - Rescinded

The Water Security Agency, is advising that the “Precautionary Drinking Water Advisory” (PDWA) issued by the Water Security Agency for the Town of Cabri ’s water distribution system has been rescinded, effective immediately.

The rescinding of the PDWA was based upon information provided by your operational staff, which included:

- The receipt of two consecutive sets of three (6 total) bacteriological samples collected 24 hours apart from the water distribution system are negative for bacteriological growth.

You may return to normal water quality monitoring requirements as detailed in your Permit to Operate a Waterworks. Thank you for your cooperation during this event. For further information please contact the undersigned at 306-741-9850 or Logan.Forester@wsask.ca.

Sincerely,



Logan Forester P.Tech.
Environment Officer
Water Security Agency

cc: Don Turner - Manager, Compliance Promotion South, WSA (email)
Water Advisories, Water Security Agency
Saskatchewan Health Authority, Swift Current Office